



- NOTES
1. 175 mm MINIMUM CLEARANCE BETWEEN WALL AND CENTRELINE OF PIPE
 2. METERS MUST BE ACCESSIBLE AND NOT BE LOCATED BEHIND FURNACE, WATER TANK, ETC.
 3. METER MAY BE INSTALLED HORIZONTALLY OR VERTICALLY
 4. NO TEES OR JUNCTIONS BEFORE METER
 5. AT LEAST 0.5m OF ARB CABLE TO BE FOLDED (DO NOT LOOP) AROUND METER
 6. ALL PRV, BACKFLOW DEVICE AND METER INSTALLATIONS TO CONFORM TO APPLICABLE CODES AND STANDARDS.

<p>REGIONAL DISTRICT OF NORTH OKANAGAN</p>		<p>TITLE TYPICAL WATER METER INSTALLATION IN BUILDING</p>			
<p>9848 Aberdeen Road, Coldstream, BC V1B 2K9 PH: 250-550-3700 FAX: 250-550-3701</p>		<p>DATE July 2015</p>	<p>SCALE N.T.S.</p>	<p>DRAWING No. W-15</p>	<p>REV. 3</p>